SOUTHERN MARIN FIRE PROTECTION DISTRICT FIRE PREVENTION

308 Reed Boulevard, Mill Valley, California 94941 Phone: (415) 289-4156 / Fax: (415) 289-4158

06/14/2012

City of Sausalito Community Development Department 420 Litho Street Sausalito, CA 94965



JUN 1 5 2012

CITY OF SAUSALITO
COMMUNITY DEVELOPMENT

Re: 2200 Bridgeway, Sausalito (Project Name: Harmonia Wellness Center) File# CUP 12-134

The proposed plans for the above-listed project have been reviewed. Based on the plans as submitted, the items noted below shall be imposed by the Southern Marin Fire Protection District in accordance with current Southern Marin Fire Protection District Ordinances.

- 1. A fire sprinkler system shall be provided for:
 - a. Existing Buildings. In any building with an existing automatic sprinkler system, protection shall be extended to any all of alteration, repair, remodel or addition, regardless of job size so that 100% coverage is maintained.
 - b.

 Fire sprinkler coverage shall be provided through the entire structure as per Uniform Fire Code Section 1001.9.
 - c. Plans for fire sprinkler system design and hydraulic calculations shall be completed by a licensed C-16 sprinkler contractor and submitted to the County Building Department/Southern Marin Fire District for approval prior to installation. Fire sprinkler system design and installation shall conform to the provisions of the County Building Department/Southern Marin Fire District and N.F.P.A. Standard(s) 13, 13D or 13R.

Final occupancy approval shall not be granted/released until authorization to the Community Development Agency has been received from the Fire District.

Sincerely,

Fire Prevention Officer