

CITY OF SAUSALITO

Sausalito, CA 94965

Addendum No. 2

Notice Issued September 30, 2013

For

Bridgeway and Caledonia Street Series Streetlight Circuit Conversion

NOTICE TO ALL PLAN HOLDERS SUBMITTING BIDS FOR THIS WORK:

You are hereby notified of the following information, changes, clarifications or modifications to the original Contract Documents, Project Manual, Drawings, Specifications and subsequent Addenda. The Addendum shall supersede the original Contract Documents and previous Addenda wherein it contradicts the same and shall take precedence over anything to the contrary therein. All other conditions remain, UNCHANGED.

This Addendum is hereby made a part of the Contract Documents to the same extent as though it were originally included therein.

Revisions:

SPECIAL PROVISIONS, CONTRACT, BID FORM AND PROPOSAL

Section 7-3.01 GENERAL of the Special Provisions is in conflict with Section 86-12 PAYMENT.

Section 86-12 Bid price for Furnish and Install Service Enclosure and Foundation shall be revised as follows:

Bid price for Furnish and Install Service Enclosure and Foundation shall include all labor, equipment, and materials required to install a fully functioning Type III-AF service equipment enclosure, including the foundation, all equipment indicated on the service wiring diagram on the plans, the conduit between the adjacent pull box and the enclosure, and all wiring and splicing in the enclosure and the adjacent pull box. The bid price shall also include coordinating connection of electrical service with the serving utility, ~~and all fees due to the serving utility~~ to complete the service connection. Payment shall be a lump sum amount.

Bid Proposal is revised as follows:

BIDDER hereby agrees to commence WORK under this contract within five (5) days of the date to be specified in the NOTICE TO PROCEED and to fully complete the PROJECT within ~~forty (40) consecutive working~~ **30 CONSECUTIVE CALENDAR** days. BIDDER further agrees to pay as liquidated damages, the sum of ~~\$350.00~~ **\$250.00** for each consecutive working day thereafter as provided in Section ~~5.06~~ **8-1.07** of the standard specifications.

Section 7-14.01, Section 86-7, Section 86-12 and the Bid Form shall be revised as follows.

Bid Item 16 “Abandon Existing Conduit (Remove & Dispose of Existing Conductors)” is deleted.

Section 7-14.01 is revised as follows:

7-14.01 ~~Bid Item 16~~ – Abandon Existing Conduit (Remove & Dispose of Existing Conductors)

~~This bid item shall be paid per linear foot as described in section 86-12 “Abandon Existing Conduit (Remove & Dispose of Existing Conductors)”.~~

Existing conductors and conduit shall be abandoned in-place except where they interfere with other construction or as required in Section 86-7.01. Existing conductors are known to be lead-sheathed and shall be disposed of in an appropriate manner as prescribed by law.

Removed conductors shall become the property of the contractor who shall remove them from the City of Sausalito for reuse, recycling or disposal in an appropriately regulated facility.

Payment for “Abandon Existing Conduit (Remove & dispose of Existing Conductors) shall be considered as included in the contract prices paid for in the other items of work and no additional compensation will be allowed therefor.

Section 86-7.01 “Removing Electrical Equipment” is revised as follows:

Existing electrical equipment, pull boxes, and conduits, to be removed and not reused or salvaged, become your property and you must dispose of it. Unused underground conduit **AND CONDUCTORS** may be abandoned in place ~~after all conductors have been removed~~ except that conduit terminations from the conduit to be abandoned must be removed from the pull boxes to remain.

Section 86-12 “Abandon Existing Conduit (Remove & Dispose of Existing Conductors)” shall be deleted.

BID OPENING DATE EXTENDED

NOTICE IS HEREBY GIVEN that the City of Sausalito will receive sealed bids for the award of the contract for public work for the above-designated project. Such sealed bids shall be received at the Office of the City Clerk of the City of Sausalito, 420 Litho Street, Sausalito, California 94965 until **Thursday October 3 at 4:00 PM**, at which time they will be publicly opened and read.

End of Revision

Comments:

The Notice to Proceed, reference Notice to Bidders, Proposal and Section 4-1.03 will not be issued until PG&E has completed its estimate for the Work.

Changes to the plans and specifications for this project as may be required should PG&E relocate the New Service location as shown on sheet four of six will be addressed by change order or by separate bid for additionally required work.

The bid extension is to provide prospective bidders with sufficient time to review these documents.

END OF ADDENDUM NO. 2

ACKNOWLEDGED

Bidder's Signature

A signed copy of this addendum is to be submitted as a part of the bid package for the subject project. Failure to do so may subject the Bidder to Disqualification.